



Product Service

# Compliance Document

No. D 119897 0012 Rev. 00

**Holder of Certificate: Hanersun Energy Co., Ltd.**

10F, B4 Block, No.19 Suyuan Avenue  
Jiangning District  
211100 Nanjing  
PEOPLE'S REPUBLIC OF CHINA

**Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-crystalline Silicon Photovoltaic module****Model(s):** HN21N-66HxxxW & HN21N-66HBxxxW, xxx=680-715 in steps of 5  
HN21N-60HxxxW & HN21N-60HBxxxW, xxx=615-650 in steps of 5  
xxx is standing for rated output power at STC**Parameters:**

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. system voltage:	1500V DC
Construction:	Framed, with Junction box, Cable and Connectors.

Remark: Modules listed above comply with the requirements of being non-sensitive to LETID.

**Tested according to:** IEC TS 63342:2022

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062424518-00**Date,** 2024-12-09

( Zhulin Zhang )